



® TM

Ref. Certif. No.

DE 2-032804

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	LED lighting lamps and lanterns with emergency lighting
Name and address of the applicant	JINYI (GUANGDONG CHINA) LIGHTING CO., LTD 1/F (area3), 4th, 5th Floor of Building 12, Qifang Industrial Park, Tongyi Industrial Zone, Guzhen Town, Zhongshan City, 528421 Guangdong Province, P.R. China
Name and address of the manufacturer	JINYI (GUANGDONG CHINA) LIGHTING CO., LTD 1/F (area3), 4th, 5th Floor of Building 12, Qifang Industrial Park, Tongyi Industrial Zone, Guzhen Town, Zhongshan City, 528421 Guangdong Province, P.R. China
Name and address of the factory	JINYI (GUANGDONG CHINA) LIGHTING CO., LTD 1/F (area3), 4th, 5th Floor of Building 12, Qifang Industrial Park, Tongyi Industrial Zone, Guzhen Town, Zhongshan City, 528421 Guangdong Province, P.R. China
Ratings and principal characteristics	AC 220-240V, 50/60Hz, 3W LED or 1.5W LED, Class II, IP65, ta: 0-40°C, self-contained, non-maintained, emergency mode duration: 180 min., LIFEP04 battery
Trademark (if any)	
Customer's Testing Facility (CTF) Stage used	N/A
Model / Type Ref.	HF-1007DA-D63, HF-1007FE-D63, HF-1007DA-D40, HF-1007FE-D40
Additional information (if necessary may also be reported on page 2)	For model differences, refer to the test report.
A sample of the product was tested and found to be in conformity with	IEC 60598-2-22:2014+A1 IEC 60598-1:2014+A1 See Test Report for National Differences
As shown in the Test Report Ref. No. which forms part of this Certificate	50400980 001

This CB Test Certificate is issued by the National Certification Body



TÜVRheinland®

TÜV Rheinland LGA Products GmbH
Tillystr. 2, 90431 Nürnberg, Germany
Phone + 49 221 806-1371
Fax + 49 221 806-3935
Mail: cert-validity@de.tuv.com
Web: www.tuv.com

Date: 2021-11-04

Signature:

Eileen Feng