



®

TM

Ref. Certif. No.

DE 2-034997

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

| | |
|---|--|
| Product | Emergency exit sign |
| Name and address of the applicant | JINYI (GUANGDONG CHINA) LIGHTING CO., LTD 1/F(area3), 4th, 5th Floor of Building 12, Qifang Industrial Park, Tongyi Industrial Zone, Guzhen Town, Zhongshan City, 528421 Guangdong Province, P.R. China |
| Name and address of the manufacturer | JINYI (GUANGDONG CHINA) LIGHTING CO., LTD 1/F(area3), 4th, 5th Floor of Building 12, Qifang Industrial Park, Tongyi Industrial Zone, Guzhen Town, Zhongshan City, 528421 Guangdong Province, P.R. China |
| Name and address of the factory | JINYI (GUANGDONG CHINA) LIGHTING CO., LTD 1/F(area3), 4th, 5th Floor of Building 12, Qifang Industrial Park, Tongyi Industrial Zone, Guzhen Town, Zhongshan City, 528421 Guangdong Province, P.R. China |
| Ratings and principal characteristics | AC 220-240V, 50/60Hz, normal mode 4W, emergency mode 1.2W Class II, IP20, ta: 0-40°C, self-contained, maintained, emergency mode duration: 180 min., LIFEP04 battery |
| Trademark (if any) | |
| Customer's Testing Facility (CTF) Stage used | N/A |
| Model / Type Ref. | HF-3132A-DA-BBW, HF-3132A-FE-BBW, HF-3132B-DA-YBW, HF-3132B-FE-YBW, HF-3132B-DA-YBB, HF-3132B-FE-YBB, HF-3132B-DA-WBW, HF-3132B-FE-WBW, HF-3132C-DA-YBW, HF-3132C-FE-YBW, HF-3132C-DA-WBW, HF-3132C-FE-WBW, HF-3132C-DA-BKB, HF-3132C-FE-BKB |
| Additional information (if necessary may also be reported on page 2) | For model differences, refer to the test report. |
| A sample of the product was tested and found to be in conformity with | IEC 60598-2-22:2014+A1 IEC 60598-1:2020 See Test Report for National Differences |
| As shown in the Test Report Ref. No. which forms part of this Certificate | 50400983 001 |

This CB Test Certificate is issued by the National Certification Body



TÜVRheinland®

TÜV Rheinland LGA Products GmbH
Tillystr. 2, 90431 Nürnberg, Germany
Phone + 49 221 806-1371
Fax + 49 221 806-3935
Mail: cert-validity@de.tuv.com
Web: www.tuv.com

Date: 2022-02-15

Signature:

Eileen Feng